

DRIFTSRAPPORT

Månedsrapport November 2019

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2115,04 m ³
Boring 1	1175,03 m ³
Boring 2	940,01 m ³
TOTAL UDPUMPET	2094,03 m ³
Udpumpning	2094,03 m ³
TOTAL SKYLLEVAND	0,00 m ³
Skyllevand	0,00 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2767 kWh
Delproces / udpumpning	868 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	7 skyl
Filter 4	7 skyl

DRIFTTIMER



BORINGER	
1	136 timer
2	216 timer
PUMPER	
1	360 timer
2	360 timer
FILTERMOTOR	
1	352 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport November 2019

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,04 m	-53,70 m	4,65 m	1175,03 m ³
2	-49,39 m	-52,98 m	3,59 m	940,01 m ³

Fordeling for indvundet vand



Blue Control®
BC7000