

DRIFTSRAPPORT

Månedsrapport December 2019

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2058,98 m ³
Boring 1	1832,57 m ³
Boring 2	226,41 m ³
TOTAL UDPUMPET	2025,86 m ³
Udpumpning	2025,86 m ³
TOTAL SKYLLEVAND	0,00 m ³
Skyllevand	0,00 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2536 kWh
Delproces / udpumpning	874 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	7 skyl
Filter 4	7 skyl

DRIFTTIMER



BORINGER	
1	211 timer
2	38 timer
PUMPER	
1	364 timer
2	380 timer
FILTERMOTOR	
1	243 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedssrapport December 2019

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,80 m	-53,58 m	4,78 m	1832,57 m ³
2	-49,01 m	-53,79 m	4,78 m	226,41 m ³

Fordeling for indvundet vand



● Boring 1 : 89.0%
● Boring 2 : 11.0%



Blue Control®
BC7000