

DRIFTSRAPPORT

Månedssrapport Juni 2022

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2103,83 m ³
Boring 1	1032,50 m ³
Boring 2	1071,33 m ³
TOTAL UDPUMPET	2062,58 m ³
Udpumpning	2062,58 m ³
TOTAL SKYLLEVAND	10,15 m ³
Skyllevand	10,15 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2113 kWh
Delproces / udpumpning	805 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	8 skyl
Filter 2	7 skyl
Filter 3	7 skyl
Filter 4	7 skyl

DRIFTTIMER



BORINGER	
1	122 timer
2	126 timer
PUMPER	
1	360 timer
2	360 timer
FILTERMOTOR	
1	247 timer
2	1 timer



Blue Control®
BC7000



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,05 m	-53,66 m	4,61 m	1032,50 m ³
2	-49,17 m	-53,85 m	4,67 m	1071,33 m ³

Fordeling for indvundet vand

