

# DRIFTSRAPPORT

Månedsrapport April 2021

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	2006,51 m <sup>3</sup>
Boring 1	998,06 m <sup>3</sup>
Boring 2	1008,45 m <sup>3</sup>
TOTAL UDPUMPET	1966,60 m <sup>3</sup>
Udpumpning	1966,60 m <sup>3</sup>
TOTAL SKYLLEVAND	0,00 m <sup>3</sup>
Skyllevand	0,00 m <sup>3</sup>

## ELFORBRUG




ELFORBRUG	
Samlet proces	2149 kWh
Delproces / udpumpning	852 kWh



## NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



## FILTRE

Filter 1	4 skyl
Filter 2	4 skyl
Filter 3	7 skyl
Filter 4	7 skyl

## DRIFTTIMER



BORINGER	
1	140 timer
2	137 timer
PUMPER	
1	360 timer
2	360 timer
FILTERMOTOR	
1	277 timer
2	1 timer



Blue Control®  
BC7000



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,65 m	-52,54 m	3,89 m	998,06 m <sup>3</sup>
2	-48,88 m	-52,95 m	4,06 m	1008,45 m <sup>3</sup>

Fordeling for indvundet vand

