

DRIFTSRAPPORT

Månedsrapport Juni 2020

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2519,66 m ³
Boring 1	1246,13 m ³
Boring 2	1273,53 m ³
TOTAL UDPUMPET	2477,41 m ³
Udpumpning	2477,41 m ³
TOTAL SKYLLEVAND	0,00 m ³
Skyllevand	0,00 m ³

ELFORBRUG



ELFORBRUG	
Samlet proces	2652 kWh
Delproces / udpumpning	939 kWh



NATFORBRUG



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	8 skyl
Filter 4	8 skyl

DRIFTTIMER



BORINGER	
1	163 timer
2	161 timer
PUMPER	
1	360 timer
2	360 timer
FILTERMOTOR	
1	323 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport Juni 2020

Faurbo Vandværk

2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,24 m	-53,05 m	4,81 m	1246,13 m ³
2	-48,96 m	-53,52 m	4,55 m	1273,53 m ³



Blue Control®
BC7000