

DRIFTSRAPPORT

Månedssrapport April 2019

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2142,61 m ³
Boring 1	1121,18 m ³
Boring 2	1021,43 m ³
TOTAL UDPUMPET	2121,70 m ³
Udpumpning	2121,70 m ³
TOTAL SKYLLEVAND	0,00 m ³
Skyllevand	0,00 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2369 kWh
Delproces / udpumpning	872 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	5 skyl
Filter 2	4 skyl
Filter 3	7 skyl
Filter 4	7 skyl

DRIFTTIMER



BORINGER	
1	125 timer
2	152 timer
PUMPER	
1	360 timer
2	360 timer
FILTERMOTOR	
1	277 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport April 2019

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,94 m	-53,69 m	4,75 m	1121,18 m ³
2	-49,18 m	-52,97 m	3,79 m	1021,43 m ³

Fordeling for indvundet vand



● Boring 1 : 52.3%
● Boring 2 : 47.7%



Blue Control®
BC7000