

# DRIFTSRAPPORT

Årsrapport 2020

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	26042,55 m <sup>3</sup>
Boring 1	12853,99 m <sup>3</sup>
Boring 2	13188,56 m <sup>3</sup>
TOTAL UDPUMPET	25625,11 m <sup>3</sup>
Udpumpning	25625,11 m <sup>3</sup>
TOTAL SKYLLEVAND	0,00 m <sup>3</sup>
Skyllevand	0,00 m <sup>3</sup>

## ELFORBRUG



ELFORBRUG	
Samlet proces	28399 kWh
Delproces / udpumpning	10641 kWh



## NATFORBRUG



## FILTRE

Filter 1	60 skyl
Filter 2	59 skyl
Filter 3	90 skyl
Filter 4	90 skyl

## DRIFTTIMER



BORINGER	
1	1628 timer
2	1645 timer
PUMPER	
1	4417 timer
2	4368 timer
FILTERMOTOR	
1	3271 timer
2	8 timer



Blue Control®  
BC7000

# DRIFTSRAPPORT

Årsrapport 2020

Faurbo Vandværk

2/2



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-47,87 m	-53,50 m	5,63 m	12853,99 m <sup>3</sup>
2	-48,59 m	-53,78 m	5,19 m	13188,56 m <sup>3</sup>



Blue Control®  
BC7000