

DRIFTSRAPPORT

Månedsrapport Februar 2021

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	1809,63 m ³
Boring 1	899,03 m ³
Boring 2	910,60 m ³
TOTAL UDPUMPET	1780,70 m ³
Udpumpning	1780,70 m ³
TOTAL SKYLLEVAND	0,00 m ³
Skyllevand	0,00 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2001 kWh
Delproces / udpumpning	789 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	4 skyl
Filter 2	4 skyl
Filter 3	6 skyl
Filter 4	6 skyl

DRIFTTIMER



BORINGER	
1	123 timer
2	122 timer
PUMPER	
1	336 timer
2	336 timer
FILTERMOTOR	
1	245 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport Februar 2021

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,84 m	-52,80 m	3,95 m	899,03 m ³
2	-49,09 m	-53,23 m	4,14 m	910,60 m ³

Fordeling for indvundet vand



Blue Control®
BC7000