

# DRIFTSRAPPORT

Månedssrapport November 2022

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	1784,51 m <sup>3</sup>
Boring 1	876,68 m <sup>3</sup>
Boring 2	907,83 m <sup>3</sup>
TOTAL UDPUMPET	1756,42 m <sup>3</sup>
Udpumpning	1756,42 m <sup>3</sup>
TOTAL SKYLLEVAND	5,55 m <sup>3</sup>
Skyllevand	5,55 m <sup>3</sup>

## ELFORBRUG




ELFORBRUG	
Samlet proces	1824 kWh
Delproces / udpumpning	754 kWh



## NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



## FILTRE

Filter 1	4 skyl
Filter 2	4 skyl
Filter 3	6 skyl
Filter 4	6 skyl

## DRIFTTIMER



BORINGER	
1	108 timer
2	111 timer
PUMPER	
1	360 timer
2	360 timer
FILTERMOTOR	
1	218 timer
2	1 timer



Blue Control®  
BC7000

# DRIFTSRAPPORT

Månedssrapport November 2022

Faurbo Vandværk


2/2



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,62 m	-53,88 m	4,26 m	876,68 m <sup>3</sup>
2	-49,51 m	-53,85 m	4,34 m	907,83 m <sup>3</sup>

Fordeling for indvundet vand



Blue Control®  
BC7000