

DRIFTSRAPPORT

Månedssrapport November 2021

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	1969,34 m ³
Boring 1	974,76 m ³
Boring 2	994,58 m ³
TOTAL UDPUMPET	1940,88 m ³
Udpumpning	1940,88 m ³
TOTAL SKYLLEVAND	0,00 m ³
Skyllevand	0,00 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2202 kWh
Delproces / udpumpning	852 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	7 skyl
Filter 4	7 skyl

DRIFTTIMER



BORINGER	
1	139 timer
2	138 timer
PUMPER	
1	360 timer
2	360 timer
FILTERMOTOR	
1	277 timer
2	1 timer



Blue Control®
BC7000



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,26 m	-53,52 m	4,27 m	974,76 m ³
2	-49,53 m	-53,56 m	4,04 m	994,58 m ³

Fordeling for indvundet vand

