

# DRIFTSRAPPORT

Månedsrapport December 2018

Faurbo Vandværk

1/2



## MÆNGDER

TOTAL INDVUNDET	1949,14 m <sup>3</sup>
Boring 1	1040,80 m <sup>3</sup>
Boring 2	908,34 m <sup>3</sup>
TOTAL UDPUMPET	1850,32 m <sup>3</sup>
Udpumpning	1850,32 m <sup>3</sup>
TOTAL SKYLLEVAND	0,00 m <sup>3</sup>
Skyllevand	0,00 m <sup>3</sup>

## ELFORBRUG




ELFORBRUG	
Samlet proces	2456 kWh
Delproces / udpumpning	841 kWh



## NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



## FILTRE

Filter 1	5 skyl
Filter 2	4 skyl
Filter 3	7 skyl
Filter 4	7 skyl

## DRIFTTIMER



BORINGER	
1	114 timer
2	130 timer
PUMPER	
1	380 timer
2	364 timer
FILTERMOTOR	
1	244 timer
2	1 timer



Blue Control®  
BC7000

# DRIFTSRAPPORT

Månedssrapport December 2018

Faurbo Vandværk


2/2



## NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,23 m	-54,18 m	4,95 m	1040,80 m <sup>3</sup>
2	-49,48 m	-53,38 m	3,90 m	908,34 m <sup>3</sup>

Fordeling for indvundet vand



● Boring 1 : 53.4%  
● Boring 2 : 46.6%



Blue Control®  
BC7000