

DRIFTSRAPPORT

Månedsrapport September 2023

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2440,41 m ³
Boring 1	1212,84 m ³
Boring 2	1227,57 m ³
TOTAL UDPUMPET	2426,50 m ³
Udpumpning	2426,50 m ³
TOTAL SKYLLEVAND	6,79 m ³
Skyllevand	6,79 m ³

ELFORBRUG




ELFORBRUG	
Samlet proces	2335 kWh
Delproces / udpumpning	865 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	8 skyl
Filter 4	8 skyl

DRIFTTIMER



BORINGER	
1	154 timer
2	155 timer
PUMPER	
1	360 timer
2	360 timer
FILTERMOTOR	
1	308 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport September 2023

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,40 m	-53,46 m	4,06 m	1212,84 m ³
2	-49,31 m	-53,55 m	4,24 m	1227,57 m ³

Fordeling for indvundet vand



● Boring 1 : 49.7%
● Boring 2 : 50.3%



Blue Control®
BC7000