

DRIFTSRAPPORT

Månedsrapport Maj 2025

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2527,35 m ³
Boring 1	1201,36 m ³
Boring 2	1325,99 m ³
TOTAL UDPUMPET	2616,47 m ³
Udpumpning	2616,47 m ³
TOTAL SKYLLEVAND	140,87 m ³
Skyllevand	140,87 m ³

ELFORBRUG




ELFORBRUG

Samlet proces	2507 kWh
Delproces / udpumpning	897 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	10 skyl
Filter 2	9 skyl
Filter 3	9 skyl
Filter 4	9 skyl

DRIFTTIMER



BORINGER

1	177 timer
2	178 timer

PUMPER

1	379 timer
2	365 timer

FILTERMOTOR

1	350 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport Maj 2025

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,86 m	-53,11 m	4,24 m	1201,36 m ³
2	-48,87 m	-53,17 m	4,30 m	1325,99 m ³

Fordeling for indvundet vand



● Boring 1 : 47.5%
● Boring 2 : 52.5%



Blue Control®
BC7000