

DRIFTSRAPPORT

Månedssrapport Januar 2025

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	1921,99 m ³
Boring 1	964,57 m ³
Boring 2	957,42 m ³
TOTAL UDPUMPET	1902,71 m ³
Udpumpning	1902,71 m ³
TOTAL SKYLLEVAND	4,23 m ³
Skyllevand	4,23 m ³

ELFORBRUG




ELFORBRUG

Samlet proces	2283 kWh
Delproces / udpumpning	787 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	4 skyl
Filter 2	4 skyl
Filter 3	7 skyl
Filter 4	7 skyl

DRIFTTIMER



BORINGER

1	146 timer
2	145 timer

PUMPER

1	380 timer
2	364 timer

FILTERMOTOR

1	291 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedssrapport Januar 2025

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,55 m	-52,24 m	3,69 m	964,57 m³
2	-48,61 m	-52,31 m	3,70 m	957,42 m³

Fordeling for indvundet vand



● Boring 1 : 50.2%
● Boring 2 : 49.8%



Blue Control®
BC7000