

DRIFTSRAPPORT

Månedsrapport Marts 2023

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2149,53 m ³
Boring 1	1086,41 m ³
Boring 2	1063,12 m ³
TOTAL UDPUMPET	2121,51 m ³
Udpumpning	2121,51 m ³
TOTAL SKYLLEVAND	6,63 m ³
Skyllevand	6,63 m ³

ELFORBRUG




ELFORBRUG

Samlet proces	2111 kWh
Delproces / udpumpning	826 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	7 skyl
Filter 4	7 skyl

DRIFTTIMER



BORINGER

1	134 timer
2	131 timer

PUMPER

1	367 timer
2	376 timer

FILTERMOTOR

1	265 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport Marts 2023

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,80 m	-53,17 m	4,37 m	1086,41 m ³
2	-48,82 m	-53,26 m	4,44 m	1063,12 m ³

Fordeling for indvundet vand



- Boring 1 : 50.5%
- Boring 2 : 49.5%



Blue Control®
BC7000