

DRIFTSRAPPORT

Månedsrapport April 2025

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2159,06 m ³
Boring 1	1071,98 m ³
Boring 2	1087,08 m ³
TOTAL UDPUMPET	2735,51 m ³
Udpumpning	2735,51 m ³
TOTAL SKYLLEVAND	454,46 m ³
Skyllevand	454,46 m ³

ELFORBRUG




ELFORBRUG

Samlet proces	2577 kWh
Delproces / udpumpning	920 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	6 skyl
Filter 2	6 skyl
Filter 3	9 skyl
Filter 4	9 skyl

DRIFTTIMER



BORINGER

1	187 timer
2	189 timer

PUMPER

1	360 timer
2	360 timer

FILTERMOTOR

1	370 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport April 2025

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,71 m	-51,97 m	3,26 m	1071,98 m ³
2	-48,69 m	-51,99 m	3,31 m	1087,08 m ³

Fordeling for indvundet vand



● Boring 1 : 49.7%
● Boring 2 : 50.3%



Blue Control®
BC7000