

DRIFTSRAPPORT

Månedsrapport Februar 2025

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	1662,69 m ³
Boring 1	830,75 m ³
Boring 2	831,94 m ³
TOTAL UDPUMPET	1644,76 m ³
Udpumpning	1644,76 m ³
TOTAL SKYLLEVAND	4,15 m ³
Skyllevand	4,15 m ³

ELFORBRUG




ELFORBRUG

Samlet proces	2014 kWh
Delproces / udpumpning	699 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	4 skyl
Filter 2	4 skyl
Filter 3	6 skyl
Filter 4	6 skyl

DRIFTTIMER



BORINGER

1	129 timer
2	128 timer

PUMPER

1	336 timer
2	336 timer

FILTERMOTOR

1	256 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport Februar 2025

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-48,57 m	-52,13 m	3,56 m	830,75 m³
2	-48,62 m	-52,19 m	3,57 m	831,94 m³

Fordeling for indvundet vand



- Boring 1 : 50.0%
- Boring 2 : 50.0%



Blue Control®
BC7000