

DRIFTSRAPPORT

Månedsrapport Juli 2025

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2260,29 m ³
Boring 1	1076,92 m ³
Boring 2	1183,37 m ³
TOTAL UDPUMPET	2108,34 m ³
Udpumpning	2108,34 m ³
TOTAL SKYLLEVAND	5,67 m ³
Skyllevand	5,67 m ³

ELFORBRUG




ELFORBRUG

Samlet proces	1918 kWh
Delproces / udpumpning	787 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	5 skyl
Filter 2	5 skyl
Filter 3	8 skyl
Filter 4	7 skyl

DRIFTTIMER



BORINGER

1	139 timer
2	138 timer

PUMPER

1	380 timer
2	364 timer

FILTERMOTOR

1	277 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedsrapport Juli 2025

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,20 m	-53,26 m	4,06 m	1076,92 m ³
2	-49,26 m	-53,33 m	4,07 m	1183,37 m ³

Fordeling for indvundet vand



● Boring 1 : 47.6%
● Boring 2 : 52.4%



Blue Control®
BC7000