

# DRIFTSRAPPORT

Månedssrapport Marts 2025

Faurbo Vandværk

1/2



## MÆNGDER

|                  |                        |
|------------------|------------------------|
| TOTAL INDVUNDET  | 1823,24 m <sup>3</sup> |
| Boring 1         | 915,61 m <sup>3</sup>  |
| Boring 2         | 907,63 m <sup>3</sup>  |
| TOTAL UDPUMPET   | 2107,91 m <sup>3</sup> |
| Udpumpning       | 2107,91 m <sup>3</sup> |
| TOTAL SKYLLEVAND | 268,48 m <sup>3</sup>  |
| Skyllevand       | 268,48 m <sup>3</sup>  |

## ELFORBRUG




### ELFORBRUG

|                        |          |
|------------------------|----------|
| Samlet proces          | 2299 kWh |
| Delproces / udpumpning | 821 kWh  |



## NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



## FILTRE

|          |        |
|----------|--------|
| Filter 1 | 5 skyl |
| Filter 2 | 5 skyl |
| Filter 3 | 8 skyl |
| Filter 4 | 8 skyl |

## DRIFTTIMER



### BORINGER

|   |           |
|---|-----------|
| 1 | 150 timer |
| 2 | 148 timer |

### PUMPER

|   |           |
|---|-----------|
| 1 | 364 timer |
| 2 | 379 timer |

### FILTERMOTOR

|   |           |
|---|-----------|
| 1 | 298 timer |
| 2 | 1 timer   |



Blue Control®  
BC7000

# DRIFTSRAPPORT

Månedsrapport Marts 2025

Faurbo Vandværk


2/2



## NIVEAUER I BORINGER

| BORING | HØJEST   | LAVEST   | SÆNKNING | MÆNGDE    |
|--------|----------|----------|----------|-----------|
| 1      | -48,61 m | -52,04 m | 3,43 m   | 915,61 m³ |
| 2      | -48,63 m | -52,06 m | 3,43 m   | 907,63 m³ |

Fordeling for indvundet vand



● Boring 1 : 50.2%  
● Boring 2 : 49.8%



Blue Control®  
BC7000