

DRIFTSRAPPORT

Månedsrapport Juni 2025

Faurbo Vandværk

1/2



MÆNGDER

TOTAL INDVUNDET	2015,97 m ³
Boring 1	941,16 m ³
Boring 2	1074,81 m ³
TOTAL UDPUMPET	1873,80 m ³
Udpumpning	1873,80 m ³
TOTAL SKYLLEVAND	4,43 m ³
Skyllevand	4,43 m ³

ELFORBRUG




ELFORBRUG

Samlet proces	2013 kWh
Delproces / udpumpning	735 kWh



NATFORBRUG

Vandforbrug mellem klokken 02.00 og 04.00



FILTRE

Filter 1	6 skyl
Filter 2	6 skyl
Filter 3	7 skyl
Filter 4	7 skyl

DRIFTTIMER



BORINGER

1	120 timer
2	124 timer

PUMPER

1	356 timer
2	363 timer

FILTERMOTOR

1	244 timer
2	1 timer



Blue Control®
BC7000

DRIFTSRAPPORT

Månedssrapport Juni 2025

Faurbo Vandværk


2/2



NIVEAUER I BORINGER

BORING	HØJEST	LAVEST	SÆNKNING	MÆNGDE
1	-49,02 m	-53,22 m	4,20 m	941,16 m³
2	-49,04 m	-53,29 m	4,25 m	1074,81 m³

Fordeling for indvundet vand



● Boring 1 : 46.7%
● Boring 2 : 53.3%



Blue Control®
BC7000